



OFFICIAL RESPONSES TO VENDOR QUESTIONS RFP #RFB-2022-GLENCLIFF-05-CLEAN

No.	Question	Answer
1.	Section 1, Introduction, Subsection 1.1, Purpose and Overview What is the capacity of the tank?	See Section 1, Introduction, Subsection 1.1, Purpose and Overview.
2.	Section 3, Scope of work, Subsection 3.2 Is there fixed drainage in the tank room that can be used to collect any water or liquids used to pressure-wash the tank?	No. The selected Bidder will provide all labor, materials, and equipment necessary to complete the services.
3.	Section 3, Scope of Work, Subsection 3.2, Paragraph 3.2.1 Will the Contractor be allowed to schedule work onsite during evenings, nights or weekends?	No. See Addendum #1.
4.	Section 3, Scope of Work, Subsection 3.2, Paragraph 3.2.5 How much sediment is in the tank?	The exact amount of sediment of in the tank is not known. It was last emptied on August 30, 2018.
5.	General Does this project require a bond in order to bid?	No
6.	General How far is the tank room from the loading dock?	Approximately 60 feet.

New Hampshire Department of Health and Human Services
Cleaning and Coating for Fire Suppression Storage Tank



No.	Question	Answer
7.	General Will the selected Bidder be allowed to stage equipment in the loading dock area?	Yes.
8.	General Will the selected Bidder have exclusive use of the corridor outside the tank room during work hours?	No. See Image 1 and Image 2.
9.	General Will the selected Bidder be allowed to run supply and discharge hoses from the tank room to the loading dock through the corridor?	Yes, but the corridor must be available for Department personnel to move carts through at all times. See Image 1 and Image 2.
10.	General Has the fire suppression storage tank ever been used to hold anything other than potable water?	No.
11.	General Have any fire suppression chemicals ever been mixed with the water that has been stored in the fire suppression storage tank.	No. The fire suppression storage tank has only been used to hold potable water.
12.	General Will the selected Bidder be allowed to park vehicles and stage equipment on the service road outside of the tank room?	Yes, with Department approval.

New Hampshire Department of Health and Human Services
Cleaning and Coating for Fire Suppression Storage Tank



No.	Question	Answer
13.	General Will the Department close the locker room and lavatory adjacent to the tank room to Department personnel during the hours the selected Bidder is working onsite?	No. The selected Bidder will be required to allow access to all parts of the facility except the tank room for Department personnel while work is in progress. See Image 1 and Image 2.
14.	General Will the door to the kitchen area in the corridor adjacent to the tank room be able to be closed while work in in progress?	Yes. See Image 2.
15.	General Has a chemical analysis been performed to identify the content of any sediment material in the tank?	No.
16.	General Does the tank room has an exhaust fan?	No. See Image 3 and Image 4.
17.	General Does the tank room have a ventilation system that can be used by the selected Bidder to provide fresh air?	No. See Image 3 and Image 4.
18.	General Are there any doors, windows, or other openings to outside in the tank room?	No. See Image 3 and Image 4.
19.	General Is there a coating on the interior of the tank?	No.

**New Hampshire Department of Health and Human Services
Cleaning and Coating for Fire Suppression Storage Tank**



No.	Question	Answer
20.	General Will the Department provide potable water for the selected Bidder to use to perform the requirements of the Scope of Work?	Yes.
21.	General Are there any hotels in the immediate area?	No. The closest hotels are located in the Woodsville and Plymouth areas.